



REPORT AND NOTICE OF INSPECTION

280 SOUTH DECATUR BLVD • LAS VEGAS, NV • 89107 • 702-759-1258 (DIRECT PLAN REVIEW) • 702-759-1110 (DIRECT FOOD OPS) • 702-759-1000 (24 HOURS)

FACILITY INFORMATION

PERMIT #	ESTABLISHMENT NAME	PHONE #	FACILITY ID			
PR0012336	Capriotti's Sandwich Shop Capriotti's Sandwich Shop	(702) 562-0440	FA0006847			
ADDRESS	8450 W Sahara AVE 116			RECORD ID DA6ARPRJK		
PERSON INTERVIEWED:		TELEPHONE:				
FACILITY TYPE: 1006 - RESTAURANT / TAKE OUT		CONTACT PERSON: Sean Acre				
CURRENT SERVICE	EHS	SERVICE	DATE	TIME IN	TIME OUT	RESULT
	EE7001088	Complaint Investigation	1/09/2018	10:30AM	11:00AM	Complaint valid without fee
SPECIAL NOTES: RPZ USM 11/20167						

Inspection Violations

No violations cited.

Inspection Temperature Observations

No Temperature Observations

Overall Inspection Comments

COMPLAINT #: CO0072883

COMPLAINANT STATES: THERE HAS BEEN A VERY FOUL ODOR COMING OUT OF THE BACK OF THIS RESTAURANT ALMOST SMELLING LIKE FECES FOR WELL OVER A WEEK. THE EMPLOYEES SAY ALL OF THEIR DRAINS ARE STOPPED UP AND FLOWING OVER. BECAUSE THEY CAN'T PUT ANYTHING IN THE DRAINS THEY ARE DUMPING FOOD, MOP WATER AND EVERYTHING ELSE IN THE ALLEY. WHEN THEY HAVE TO BAIL OUT A DRAIN FROM OVERFLOWING THEY DUMP IT IN THE MOP BUCKET AND THROW IT IN THE ALLEY. THEN WHEN MOP TIME COMES THEY FILL THE BUCKET UP WITHOUT WASHING IT. SOME OF THE EMPLOYEES ARE HOLDING SOMETHING OVER THEIR NOSES BECAUSE IT IS SO RANCID FROM THE KITCHEN ON BACK. THEY SAY THE STORE MANAGER, MILLION, IS WELL AWARE BUT THEY ARE AFRAID TO REPORT IT.

INSPECTOR OBSERVATION: This complaint is investigated in conjunction with COMPLAINT #CO0072872.

No foul odors were observed anywhere in the facility. Employees are aware of the pipes backing up.

All food handlers and supervisor were aware of the situation. According to them, they have been contacting corporate to get their pipes fixed for awhile. Catch bins were observed under front handsink and under 3-compartment sink. Supervisor filled 1st basin with water 2/3 full, and attempted to drain; the floor sink backed up immediately. EHS left front handsink running for a few seconds before floor sink under 3-compartment sink started backing up even more.

No active leaks were observed under any of the sinks during the investigation. According to all food handlers, they take the bins filled with waste water and dump it outside into a storm drain.

Food handlers are unable to wash hands or warewash as floor drain backs up immediately after sinks turn on. The only working handsink is inside the employee restroom.

Other observations noted:

Active leak from ceiling at 3 different locations throughout the facility: in front dining area, on prep table in kitchen, and front prep area. Food handler observed food handling next to the active leak on prep table.

Facility is closed . Facility must make repairs so pipes drain properly. Additionally, the roof and ceiling must be repaired so no leaks occur anywhere in the facility.

You must cease and desist dumping anything outside. Solid Waste may follow up to verify compliance.

A routine inspection has also been conducted. See inspection report for more details.

Complaint valid without a fee (valid complaint fee and closure fee was assessed with CO0072872).



REPORT AND NOTICE OF INSPECTION

280 SOUTH DECATUR BLVD • LAS VEGAS, NV • 89107 • 702-759-1258 (DIRECT PLAN REVIEW) • 702-759-1110 (DIRECT FOOD OPS) • 702-759-1000 (24 HOURS)

FACILITY INFORMATION

PERMIT #	ESTABLISHMENT NAME	PHONE #	FACILITY ID			
PR0012336	Capriotti's Sandwich Shop Capriotti's Sandwich Shop	(702) 562-0440	FA0006847			
ADDRESS 8450 W Sahara AVE 116				RECORD ID DA6ARPRJK		
PERSON INTERVIEWED:			TELEPHONE:			
FACILITY TYPE: 1006 - RESTAURANT / TAKE OUT			CONTACT PERSON: Sean Acre			
CURRENT SERVICE	EHS	SERVICE	DATE	TIME IN	TIME OUT	RESULT
	EE7001088	Complaint Investigation	1/09/2018	10:30AM	11:00AM	Complaint valid without fee
SPECIAL NOTES: RPZ USM 11/20167						

	REPORT AND NOTICE OF INSPECTION	Facility Name:	Date:	Page 2 of 2
	PR0012336	Capriotti's Sandwich Shop	01/09/2018	

Received by (signature)	Received by (printed)	EHS (signature)
	Sean Acre Area Manager	 Marissa Stanley